

2011 Woss Annual Water Report

February 20, 2012

General Information

Period of Monitoring Covered by this Report:	January 1, 2011 to December 31, 2011
Water Supply System Operating Permit Number:	1440197
Location of Water Supply System:	Community of Woss with water being sourced from two wells located in the community.
Name of Owners:	Regional District of Mount Waddington
Report Contact Person:	Patrick Donaghy (250) 956-3301 pdonaghy@rdmw.bc.ca

Monitoring Results

Monitoring for coliform/E-coli as per section 11 of the Act and section 8 of the Regulation. See Water Sample Range Report for Woss in 2011 at <http://www.rdmw.bc.ca> under the Woss page.

Results of monitoring for any other parameters required by the Operating Permit. No additional parameters required.

Results of any additional monitoring required by the Drinking Water Officer during the year. No additional requirements set by the Drinking Water Officer.

Improvement Actions and Plans

- Indicated the steps taken to address circumstances in which monitored parameters exceeded permitted levels and to avoid similar occurrences in the future.
 - In the two instances where exceedences were recorded, problem locations were flushed and samples retaken.
- Indicate improvements or remedial actions that are required by the operating permit or Drinking Water Officer, and required timelines for such improvements or remedial actions.
 - Broad spectrum analysis will be undertaken of the water supply in 2012.
- Indicate any additional plans for improvements, including timelines.
 - Surge protection infrastructure was installed in January 2012.