

2015 Woss Annual Water Report

July 26, 2016

General Information

Period of Monitoring Covered by this Report:	January 1, 2015 to December 31, 2015
Water Supply System Operating Permit Number:	1440197
Location of Water Supply System:	Community of Woss with water being sourced from two wells located in the community.
Name of Owners:	Regional District of Mount Waddington
Report Contact Person:	Patrick Donaghy (250) 956-3301 pdonaghy@rdmw.bc.ca

Monitoring Results

Monitoring for coliform/E-coli as per section 11 of the Act and section 8 of the Regulation. See Water Sample Range Report for Woss in 2014 at <http://www.rdmw.bc.ca> under the Woss page.

Results of monitoring for any other parameters required by the Operating Permit. No additional parameters required.

Results of any additional monitoring required by the Drinking Water Officer during the year. No additional requirements set by the Drinking Water Officer.

Improvement Actions and Plans

- Indicated the steps taken to address circumstances in which monitored parameters exceeded permitted levels and to avoid similar occurrences in the future.
 - In the instances where exceedances were recorded, problem locations were flushed and samples retaken.
- Indicate improvements or remedial actions that are required by the operating permit or Drinking Water Officer, and required timelines for such improvements or remedial actions.
 - None required.
- Indicate any additional plans for improvements, including timelines.
 - Network of flow meter stations were established in 2015.

Please distribute this report to all users who are dependent upon you for the supply of potable water provided by the Woss Water System

To assist those interested in the following water quality results, the information should aid readers in interpreting the results for the Woss Water Service and what is considered acceptable for drinking water:

E. Coli

- No *E. Coli* detectable per 100 ml of each water sample.

Coliform

- If *only one sample* is taken in a 30-day period:
No detectable Coliform per 100 ml of water
- If *more than one sample* is taken in a 30-day period:
At least 90% of samples will have no detectable Coliform per 100 ml of water, and
No sample has more than 10 total Coliform per 100ml of water

Interpreting Sample Reports

In VIHA, the results of drinking water sampling are reported using the following coding system:

- **L1** Less than 1 (no detectable bacteria) – Meaning: No bacteria present
- **OG** Overgrown – Meaning: Too many background bacteria to give an accurate count
- **EST** Estimated Count
and
- **A** Sample not tested; Too long in transit
- **C** Sample leaked/broken in transit
- **D** Sample not tested; No collection date given
- **T** Sample submitted unsatisfactory. Exceeded 30 hours holding time, please resample.
- **NS** No sample received with requisition

WOSS HAMLET

Facility Location:

2044 McNeill Road
Woss

Facility Information:

Facility Type: DWC

Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Woss School, Woss, B.C.	28-Jun-2016	L1	L1
Woss Vegas Cafe, Woss, B.C.	28-Jun-2016	L1	L1
Woss School, Woss, B.C.	30-May-2016	L1	L1
Woss Vegas Cafe, Woss, B.C.	30-May-2016	L1	L1
Woss School, Woss, B.C.	25-Apr-2016	L1	L1
Woss Vegas Cafe, Woss, B.C.	25-Apr-2016	L1	L1
Woss Vegas Cafe, Woss, B.C.	29-Mar-2016	L1	L1
Woss School, Woss, B.C.	29-Feb-2016	L1	L1
Woss Vegas Cafe, Woss, B.C.	29-Feb-2016	L1	L1
Woss School, Woss, B.C.	25-Jan-2016	L1	L1
Woss Vegas Cafe, Woss, B.C.	25-Jan-2016	L1	L1
Woss School, Woss, B.C.	15-Dec-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	15-Dec-2015	L1	L1
Woss School, Woss, B.C.	23-Nov-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	23-Nov-2015	L1	L1
Woss School, Woss, B.C.	27-Oct-2015	L1	L1

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
Woss Vegas Cafe, Woss, B.C.	27-Oct-2015	L1	L1
Woss School, Woss, B.C.	22-Sep-2015	A	
Woss Vegas Cafe, Woss, B.C.	22-Sep-2015	A	
Pool Sink, Gen Del, Woss, Bc	18-Aug-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	18-Aug-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	7-Jul-2015	L1	L1
Woss School, Woss, B.C.	26-May-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	26-May-2015	L1	L1
Woss School, Woss, B.C.	28-Apr-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	28-Apr-2015	L1	L1
Woss School, Woss, B.C.	17-Mar-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	17-Mar-2015	L1	L1
Woss School, Woss, B.C.	24-Feb-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	24-Feb-2015	L1	L1
Woss School, Woss, B.C.	26-Jan-2015	L1	L1
Woss Vegas Cafe, Woss, B.C.	26-Jan-2015	L1	L1